

## SECTION 22 1423 - STORM DRAINAGE PIPING SPECIALTIES

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Roof drains.
  - 2. Deck drains
  - 3. Miscellaneous storm drainage piping specialties.
  - 4. Cleanouts.
  - 5. Flashing materials.

#### 1.3 SUBMITTALS

- A. Product Data: For each type of product indicated.

#### 1.4 QUALITY ASSURANCE

- A. Drainage piping specialties shall bear label, stamp, or other markings of specified testing agency.

### PART 2 - PRODUCTS

#### 2.1 ROOF AND DECK DRAINS

- A. Cast-Iron, Large-Sump, General-Purpose Roof Drains **RD** and **ED**:
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Josam Company.
    - b. Smith, Jay R. Mfg. Co.
    - c. Tyler Pipe; Wade Div.
    - d. Zurn Plumbing Products Group; Specification Drainage Operation.
  - 2. Standard: ASME A112.6.4, for general-purpose roof drains.
  - 3. Body Material: Cast iron.
  - 4. Dimension of Body: Nominal 15-inch diameter.

5. Combination Flashing Ring and Gravel Stop: Not required.
6. Flow-Control Weirs: Not required.
7. Outlet Location: Bottom.
8. Outlet Size: As indicated on drawings.
9. Extension Collars: Not required.
10. Underdeck Clamp: Required.
11. Expansion Joint: Not required.
12. Dome Material: PE.
13. Water Dam: 2 inches high on **ED only**.

B. Deck Drains **DD**:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company.
  - b. Smith, Jay R. Mfg. Co.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation.
2. Standard: ASME A112.21.2, for drains.
3. Body Material: Cast iron.
4. Dimension of Body: Nominal 8 inch diameter.
5. Grate: Coated cast iron 8 inches square.
6. Outlet Location: Bottom.
7. Outlet Size: As indicated on drawings.

2.2 MISCELLANEOUS STORM DRAINAGE PIPING SPECIALTIES

A. Downspout Boots:

1. Description: Manufactured, ASTM A 48/A 48M, gray-iron casting, with strap or ears for attaching to building; 4 inch outlet; and shop-applied bituminous coating.
2. Size: Inlet size to match downspout and 4 inch outlet.

B. Conductor Nozzles for Emergency Drain:

1. Description: Nickel bronze body with threaded inlet and nickel bronze wall flange with mounting holes.
2. Size: Same as connected conductor.

2.3 CLEANOUTS

A. Floor Cleanouts **FCO**:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company.
  - b. Smith, Jay R. Mfg. Co.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation..

2. Standard: ASME A112.36.2M, for adjustable housing cleanouts.
3. Size: Same as connected branch.
4. Type: Adjustable housing.
5. Body or Ferrule Material: ABS.
6. Clamping Device: Required.
7. Outlet Connection: Inside calk.
8. Closure: Plastic plug.
9. Adjustable Housing Material: ABS Plastic with threads.
10. Frame and Cover Material and Finish: Scoriated Nickel-bronze, copper alloy.
11. Frame and Cover Shape: Round.
12. Top-Loading Classification: Medium Duty.

## B. Test Tees:

1. Standard: ASME A112.36.2M and ASTM A 74, ASTM A 888, or CISPI 301, for cleanout test tees.
2. Size: Same as connected drainage piping.
3. Body Material: Hub-and-spigot, cast-iron soil-pipe T-branch or hubless, cast-iron soil-pipe test tee as required to match connected piping.
4. Closure Plug: raised head, brass.
5. Closure Plug Size: Same as or not more than one size smaller than cleanout size.

C. Wall Cleanouts **WCO**:

1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
  - a. Josam Company.
  - b. Smith, Jay R. Mfg. Co.
  - c. Tyler Pipe; Wade Div.
  - d. Zurn Plumbing Products Group; Specification Drainage Operation..
2. Standard: ASME A112.36.2M, for cleanouts. Include wall access.
3. Size: Same as connected drainage piping.
4. Body Material: Hubless, cast-iron soil-pipe test tee as required to match connected piping.
5. Closure: Countersunk, drilled-and-threaded brass plug.
6. Closure Plug Size: Same as or not more than one size smaller than cleanout size.
7. Wall Access: Round, flat, chrome-plated brass or stainless-steel cover plate with screw.

## 2.4 FLASHING MATERIALS

- A. Copper Sheet: ASTM B 152/B 152M, 12 oz./sq. ft..
- B. Zinc-Coated Steel Sheet: ASTM A 653/A 653M, with 0.20 percent copper content and 0.04-inch minimum thickness unless otherwise indicated. Include G90 hot-dip galvanized, mill-phosphatized finish for painting if indicated.
- C. Elastic Membrane Sheet: ASTM D 4068, flexible, chlorinated polyethylene, 40-mil minimum thickness.
- D. Fasteners: Metal compatible with material and substrate being fastened.

- E. Metal Accessories: Sheet metal strips, clamps, anchoring devices, and similar accessory units required for installation; matching or compatible with material being installed.
- F. Solder: ASTM B 32, lead-free alloy.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Install roof drains at low points of roof areas according to roof membrane manufacturer's written installation instructions. Roofing materials are specified in Division 07 Sections.
  - 1. Install flashing collar or flange of roof drain to prevent leakage between drain and adjoining roofing. Maintain integrity of waterproof membranes where penetrated.
  - 2. Install expansion joints, if indicated, in roof drain outlets.
  - 3. Position roof drains for easy access and maintenance.
- B. Install downspout boots at grade with top 12 inches above grade. Secure to building wall.
- C. Install conductor nozzles at exposed bottom of conductors where they spill onto grade.
- D. Install cleanouts in aboveground piping and building drain piping according to the following instructions unless otherwise indicated:
  - 1. Use cleanouts the same size as drainage piping up to NPS 4. Use NPS 4 for larger drainage piping unless larger cleanout is indicated.
  - 2. Locate cleanouts at each change in direction of piping greater than 45 degrees.
  - 3. Locate cleanouts at minimum intervals of 100 feet.
  - 4. Locate cleanouts at base of each vertical soil and waste stack.
- E. For floor cleanouts for piping below floors, install cleanout with top flush with finished floor.
- F. For cleanouts located in concealed piping, install cleanout wall access covers, of types indicated, with frame and cover flush with finished wall.
- G. Install test tees in vertical conductors and near floor.
- H. Install wall cleanouts in vertical conductors. Install access door in wall if indicated.
- I. Install sleeve flashing device with each conductor passing through floors with waterproof membrane.

#### 3.2 CONNECTIONS

- A. Comply with requirements for piping specified in Division 22 Sections. Drawings indicate general arrangement of piping, fittings, and specialties.

3.3 FLASHING INSTALLATION

- A. Fabricate flashing from single piece of metal unless large pans, sumps, or other drainage shapes are required. Join flashing according to the following if required:
  - 1. Lead Sheets: Burn joints of 6.0-lb/sq. ft. lead sheets, 0.0938-inch thickness or thicker. Solder joints of 4.0-lb/sq. ft. lead sheets, 0.0625-inch thickness or thinner.
  - 2. Copper Sheets: Solder joints of copper sheets.
- B. Install sheet flashing on pipes, sleeves, and specialties passing through or embedded in floors and roofs with waterproof membrane.
  - 1. Pipe Flashing: Sleeve type, matching the pipe size, with a minimum length of 10 inches and with skirt or flange extending at least 8 inches around pipe.
  - 2. Sleeve Flashing: Flat sheet, with skirt or flange extending at least 8 inches around sleeve.
  - 3. Embedded Specialty Flashing: Flat sheet, with skirt or flange extending at least 8 inches around specialty.
- C. Set flashing on floors and roofs in solid coating of bituminous cement.
- D. Secure flashing into sleeve and specialty clamping ring or device.
- E. Fabricate and install flashing and pans, sumps, and other drainage shapes.

3.4 PROTECTION

- A. Protect drains during remainder of construction period to avoid clogging with dirt or debris and to prevent damage from traffic or construction work.
- B. Place plugs in ends of uncompleted piping at end of each day or when work stops.

**END OF SECTION 22 1423**

NORTHWESTERN UNIVERSITY  
PROJECT NAME \_\_\_\_\_  
JOB # \_\_\_\_\_

FOR: \_\_\_\_\_  
ISSUED: 03/29/2017

THIS PAGE IS INTENTIONALLY BLANK